

Be Shine Textile Inc.

TEST REPORT

SCOPE OF WORK

Printed and embroidered flame-retardant seamless wall covering

REPORT NUMBER

191230016SHF-001

TEST DATE(S)

2019-12-30 - 2020-01-16

ISSUE DATE


2020-01-16

PAGES

5

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2019) © 2020 INTERTEK



Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch
Plant 5, No. 6958 Daye Road, Fengxian District, Shanghai, China
Tel: 021-61136116 Fax: 021-61189921

Website: www.intertek.com

Test Report

Statement

- 1. This report is invalid without company's special seal for testing on assigned page.
- 2. This report is invalid without authorized person's signature.
- 3. This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.

5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.

6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.

Version: 1 May 2019 Page 2 of 5 LFT-APAC-SHF-OP-10k



Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch Plant 5, No. 6958 Daye Road, Fengxian District, Shanghai, China Tel: 021-61136116 Fax: 021-61189921

Website: www.intertek.com

Test Report

Issue Date: 2020-01-16 Intertek Report No. 191230016SHF-001

Applicant: Be Shine Textile Inc.

Address: 63 McCarty Crescent, L3P 4R5, Markham, ON, Ca

Attn: Sun, Jin

Test Type: Performance test, samples provided by the applicant.

Product Information

Product Name	Printed and embroidered flame-retardant seamless wall covering		Brand	Be Shine
Sample	Cood Condition		Sample Amount	1 pieces
Description		Good Condition	Received Date	2019-12-27
Sample ID		Model	Specification	
S191230016SHF.006		Ingredients: 100% flame retardant polyester fiber. 310 g / square meter. Model: YXZ	Three meters wide	

Test Methods And Standards

TCSC IVICCIIOUS AII	
Test Standard	ASTM E84-19b
Specification Standard	
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1. This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.

Report Authorized

Name: Harrison Li

Title: Reviewer

Version: 1 May 2019

Tod Qian Project Engineer

检测专用量都办法

Qian

Page 3 of 5 LFT-APAC-SHF-OP-10k



Test Report

Issue Date: 2020-01-16 Intertek Report No. 191230016SHF-001

Test Items, Method and Results:

Test Method: ASTM E84-19b Standard Test Method for Surface Burning Characteristics of Building Materials

Specimen Mounting Method:

The 24.01-ft. long test specimen was consisted of two 12.00-ft. long x 24.00-in. wide x 0.028-in. thick "Printed and embroidered flame-retardant seamless wall covering".

The side with pattern was exposed to fire.

The specimen was supported with 0.25-in. diameter metal rods that were spaced approximately every two feet and 20-gage, 2-in. hexagonal galvanized steel netting at the request of the sponsor.


Test Observation (min:sec)

Melting	Blistering	Transient Ignition	Steady Ignition	Flaming drops
0:08	/	/	0:25	/
Delamination	Sagging	Shrinkage	Falling	Floor Flame
/	/	/	/	7:47

Test Result


Flame Spread Index (FSI)	5	Smoke Developed Index(SDI)	150	
--------------------------	---	----------------------------	-----	--

Flame spread graph



Time (Sec)

Smoke developed graph



Time (Sec)



Test Report

Issue Date: 2020-01-16 Intertek Report No. 191230016SHF-001

Appendix A: Sample Received Photo





Front View (Test side)

Back View

Revision:

NO.	Date	Changes	Author	Reviewer
191230016SHF-001	2020-01-16	First issue	Tod Qian	Harrison Li